



NO.	DATE	BY	REVISION

UNIVERSAL TANK & IRON WORKS, INC.
INDIANAPOLIS, INDIANA

ENGINEER APPROVAL

ERECTION DRAWING
1000,000 GAL. 163'-0" TO HWL.
FOR: CARY, N. CAROLINA

DRWN BY: I.D.

DATE: 3-14-74
SCALE: NONE
CHECKED: V.L.R.

NOTE: CREW FOREMAN TO CHECK FOUNDATION SQUARE & DIAMETER BEFORE ERECTION. DIAMETER = 75'-0 7/8" SQUARE = 25'7 1/16"

ERECTION CREW TO GROUT 1" UNDER ALL BASE PLATES.

12" OVERFLOW TO DRAIN INTO WATER SEAL PIT