


- PROPOSED SEWER MANHOLE
- EXISTING SEWER MANHOLE
- ⊕ PROPOSED WATER VALVE
- ⊕ WATERLINE CROSS
- ⊕ WATERLINE TEE
- FIRE HYDRANT
- ⊕ BLOW-OFF ASSEMBLY

NOTES :

- 1). IT IS THE CONTRACTORS RESPONSIBILITY TO VERIFY LOCATION OF ALL EXISTING UTILITIES.
- 2). ALL WORK SHALL BE DONE IN CONFORMANCE WITH TOWN OF CARY STANDARDS AND SPECIFICATIONS.
- 3). THE OWNER SHALL CONTACT AND COORDINATE WITH C.P.&L. TO DEVELOP A STREET LIGHTING PLAN.
- 4). THE OWNER IS RESPONSIBLE FOR ALL INSTALLATION COSTS ASSOCIATED WITH THE STREET LIGHTING PLAN.
- 5). PROJECTED SANITARY SEWER FLOW = 100 LOTS x 280 GPD = 28,000 GPD.
- 6). ALL WATERLINES TO BE DUCTILE IRON PIPE.
- 7). ALL SEWER LINE TO BE 8" PVC SDR-35

Linear Feet of Street = 5,100 LF.  
 Linear Feet of Sanitary Sewer = 6,400 LF.  
 Linear Feet of 8" Water Line = 4,820 LF.  
 Linear Feet of 4" Water Line = 480 LF.



SF-A

UTILITIES

**Hugh J. Gilleece and Associates**  
 875 Walnut St. Suite 350 Cary, NC ph(919)460-1101 fax(919)460-7637

Revisions:  
 1ST PRELIMINARY SUBMITAL

(H) Scale: 1"=100 ft.	Designed by:	Sheet: <b>2</b>
(V) Scale: 1"=5 ft.	Drawn by:	
Date: 12/18/1998		