

1.01 EXCAVATION

- 1.01 EXCAVATION: A. In performing the excavation, the Contractor shall retain sufficient clean earth for all backfilling or grading.

- 1.02 SITE CLEARING: A. Site shall be cleared of any improvements or obstructions within the entire area to be developed or as shown on the drawings.

- 1.03 ALLOWANCE TOLERANCES: A. Location: The maximum allowable variation of the center of the top of any pier for the named locations shall be four percent of the shaft diameter or 2 inches, whichever is less.

- 1.04 PLACING CONCRETE: Comply with Concrete Specification.

- 1.05 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.06 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

- 1.07 SURFACE TREATMENT: Concrete work shall receive two applications of a mixture of 10% linseed oil and 90% mineral spirits. Each coat shall be applied at a rate of 100 square feet per gallon with a roller.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

- 1.05 BACKFILLING: A. Areas under paving and building shall be rolled with a sheeps-foot roller for soils containing clay or silt (i.e., cohesive soils).

- 1.06 GRADING: A. Uniformly compact backfill and grade areas to indicate slope with a tolerance of 1/2 inch above or below required elevation.

- 1.07 PROTECTION: A. Concealed subsurface conditions: Variations with conditions shown on the soil report shall be adjusted as described in the General Conditions and Section 1.04 of the Earthwork Specifications.

- 1.08 METALS, PAVING, CURBS AND WALLS: A. Exposed surfaces of curbs and retaining walls shall have a smooth finish. Remove fins and projections, patch defective areas with cement grout, and rub with carborundum brick and cement mortar to a smooth uniform texture.

- 1.09 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.10 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

- 1.05 BACKFILLING: A. Areas under paving and building shall be rolled with a sheeps-foot roller for soils containing clay or silt (i.e., cohesive soils).

- 1.06 GRADING: A. Uniformly compact backfill and grade areas to indicate slope with a tolerance of 1/2 inch above or below required elevation.

- 1.07 PROTECTION: A. Concealed subsurface conditions: Variations with conditions shown on the soil report shall be adjusted as described in the General Conditions and Section 1.04 of the Earthwork Specifications.

- 1.08 METALS, PAVING, CURBS AND WALLS: A. Exposed surfaces of curbs and retaining walls shall have a smooth finish. Remove fins and projections, patch defective areas with cement grout, and rub with carborundum brick and cement mortar to a smooth uniform texture.

- 1.09 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.10 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

- 1.05 BACKFILLING: A. Areas under paving and building shall be rolled with a sheeps-foot roller for soils containing clay or silt (i.e., cohesive soils).

- 1.06 GRADING: A. Uniformly compact backfill and grade areas to indicate slope with a tolerance of 1/2 inch above or below required elevation.

- 1.07 PROTECTION: A. Concealed subsurface conditions: Variations with conditions shown on the soil report shall be adjusted as described in the General Conditions and Section 1.04 of the Earthwork Specifications.

- 1.08 METALS, PAVING, CURBS AND WALLS: A. Exposed surfaces of curbs and retaining walls shall have a smooth finish. Remove fins and projections, patch defective areas with cement grout, and rub with carborundum brick and cement mortar to a smooth uniform texture.

- 1.09 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.10 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

1.01 EXCAVATION

- 1.01 EXCAVATION: A. In performing the excavation, the Contractor shall retain sufficient clean earth for all backfilling or grading.

- 1.02 SITE CLEARING: A. Site shall be cleared of any improvements or obstructions within the entire area to be developed or as shown on the drawings.

- 1.03 ALLOWANCE TOLERANCES: A. Location: The maximum allowable variation of the center of the top of any pier for the named locations shall be four percent of the shaft diameter or 2 inches, whichever is less.

- 1.04 PLACING CONCRETE: Comply with Concrete Specification.

- 1.05 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.06 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

- 1.07 SURFACE TREATMENT: Concrete work shall receive two applications of a mixture of 10% linseed oil and 90% mineral spirits. Each coat shall be applied at a rate of 100 square feet per gallon with a roller.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

1.01 EXCAVATION

- 1.01 EXCAVATION: A. In performing the excavation, the Contractor shall retain sufficient clean earth for all backfilling or grading.

- 1.02 SITE CLEARING: A. Site shall be cleared of any improvements or obstructions within the entire area to be developed or as shown on the drawings.

- 1.03 ALLOWANCE TOLERANCES: A. Location: The maximum allowable variation of the center of the top of any pier for the named locations shall be four percent of the shaft diameter or 2 inches, whichever is less.

- 1.04 PLACING CONCRETE: Comply with Concrete Specification.

- 1.05 CONCRETE JOINTS: A. Contractor shall provide construction, expansion, and control joints as indicated or required.

- 1.06 REPAIR OF DEFECTIVE CONCRETE SURFACES: Do not patch defective concrete until examined and approved by the Owner. Where so approved, make repairs in accordance with detailed instructions given by the Owner.

- 1.07 SURFACE TREATMENT: Concrete work shall receive two applications of a mixture of 10% linseed oil and 90% mineral spirits. Each coat shall be applied at a rate of 100 square feet per gallon with a roller.

593G/1 06/07/89 593G/2 06/07/89 593G/3 06/07/89

BP OIL COMPANY RETAIL MARKETING DESIGN AND ENGINEERING 200 PUBLIC SQUARE CLEVELAND, OHIO 44114 STANDARD SPECIFICATIONS DWG NO. BP-5-1 REV. DATE 7/27/84