

REC'D APR 17 1987



April 16, 1987

Ms. S. Sudano
Mr. J. Canfield
Town of Cary Engineering Department
Cary Town Hall
316 North Academy Street
Cary, N. C. 27511

Re: Cary Fire Station No. 4
Drainage - North Property Line

Ms. Sudano and Mr. Canfield:

This is a memorandum of understanding of our meeting at the Cary Fire Station No. 4 site on April 10, 1987 to discuss storm drainage. Chief Sam Matthews, Cary Fire Department was also in attendance as were representatives of the General Contractor.

The drawings require the removal of an existing 18" R.C.P., the building of a catch basin and then the installation of a new 18" R.C.P. from the new catch basin to an existing catch basin. Due to the presence of underground utilities crossing over the existing pipe to be removed, it is not practical to remove the pipe. It was agreed to build the catch basin over the end of the existing pipe and to extend a 15" R.C.P. southward to a new junction box. The specified line from the junction box (shown on the drawings) southeast of the new junction box shall be realigned to enter the new junction box.

These changes were discussed with and approved by Ms. Sudano and Mr. Canfield.

W.B. Keener
W. B. Keener, AIA
Sears, Hackney, Smith, Keener & Williams, Inc.

cc: Ned Perry, Chief C.F.D
Wayne House, Asst. Chief C.F.D
Sam Matthews, Asst. Chief C.F.D

1142 EXECUTIVE CIRCLE

CARY, NORTH CAROLINA 27511

919/487-8703

