



EXIST. 12" DI. WATER MAIN 8" S.S.
 3" FORCE MAIN TO EXISTING M.H. IN HOWLAND AVE. AT BAYOAK DRIVE. SEE SHEET B.

- LEGEND**
- ▶ REDUCER
 - BLOW-OFF ASSEMBLY W/ 2" GATE VALVE
 - 3/4" WATER SERVICE W/ METER
 - GATE VALVE
 - 4" SEWER SERVICE & CLEANOUT

TO BE CONSTRUCTED IN ACCORDANCE WITH CITY OF CARY STANDARDS AND SPECIFICATIONS
 10' HORIZONTAL SEPERATION BETWEEN ALL WATER AND SEWER LINES
 18" VERTICAL SEPERATION BETWEEN WATER LINES AND SEWER LINES OR STORM DRAINS

SEAL <i>Glenn D. Ward</i> DATE: 5-15-84		Date	5-15-84	WATER & SEWER PLAN DUTCHESS VILLAGE SEC. 3 CARY, WAKE COUNTY, N.C.	SHEET 2 OF 9
		Scale	1" = 60'		
DATE: 5-15-84		Drn By	M.T.B.	GLENN D. WARD & ASSOCIATES CIVIL ENGINEERS 301 EAST DURHAM ROAD CARY, N.C. PHONE: 467-0207	
		Field Ek.	G.J.W.		