



STANDARD REACTION BLOCKING

REV. NO. 6.12

MINIMUM CONCRETE BLOCKING (C.Y.) *					
PIPE DIA. IN.	4\"/>				
4	1/3	1/3	1/3	1/3	1/3
6	1/3	1/3	1/3	1/3	1/3
8	1/3	1/3	1/3	1/3	1/3
10	2/3	3/4	1/2	1/3	1/3
12	3/4	1.0	2/3	1/3	1/3
14	1.0	1-1/2	3/4	1/2	1/3
18	1-1/3	2.0	1.0	1/2	1/3
18	1-2/3	2-1/3	1-1/3	2/3	1/3
20	2.0	3.0	1-2/3	3/4	1/2
24	3.0	4-1/3	2-1/3	1-1/3	2/3

* CONCRETE SHALL BE 3000 P.S.I.



CONSTRUCTION DRAWINGS

REV. NO.	DESCRIPTION	DATE

DESIGNED	DATE
DRAWN	DATE
CHECKED	DATE
PROJ. ENGR.	DATE

MCKIM & CREED
 ENGINEERS • PLANNERS • SURVEYORS
 WILMINGTON, NORTH CAROLINA RALEIGH, NORTH CAROLINA
 SMITHFIELD, NORTH CAROLINA

WATERFORD FOREST APARTMENTS
 CARY, NC

UTILITIES DETAILS

DATE: 6 JAN 1995	SCALE: HORIZONTAL: NOTED VERTICAL:	SHEET NO. 25
MCE PROJ. # 0976-0007		OF 27
DWG FILE # 568F4DET		